

TABLE OF CONTENTS

- A. Construction Requirements
- B. Deflection and Haunching
- C. Fiber Reinforced Polymer (FRP) Wrap for Concrete Beams
- D. Non-Destructive Testing
- E. Structural Steel Requirements
- F. Reconfigure Existing Structural Steel
- G. Removal of Existing Bearings

	MISSOURI HIGHWAYS AND TRANSPORTATION COMMISSION 105 W. CAPITOL AVE. JEFFERSON CITY, MO 65101 Phone (888) 275-6636
	George Butler Associates, Inc. 16305 Swingley Ridge Road Chesterfield, Missouri 63017 Certificate of Authority # 000133 Consultant Phone # 913-492-0400
	If a seal is present on this sheet, JSP's has been electronically sealed and dated.
	JOB NO. J3P3203 Pettis County, MO Date Prepared: 10/2/2023
Only the following items of the Job Special Provisions (Bridge) are authenticated by this seal: A - G	

JOB SPECIAL PROVISIONS (BRIDGE)

A. CONSTRUCTION REQUIREMENTS

1.0 Description. This provision contains general construction requirements for this project.

2.0 Construction Requirements. The plans and the asbestos and lead inspection report for the existing structure(s) are included in the contract in the bridge electronic deliverables zip file for informational purposes only.

2.1 In order to assure the least traffic interference, the work shall be scheduled so that the bridge closure is for the absolute minimum amount of time required to complete the work. The bridge shall not be closed until material is available for continuous construction and the contractor is prepared to diligently pursue the work until the closed bridge is opened to traffic.

2.2 Qualified special mortar shall be a qualified rapid set concrete patching material in accordance with [Sec 704](#). A qualified rapid set concrete patching material will not be permitted for half-sole repair, deck repair with void tube replacement, full depth repair, modified deck repair and substructure repair (formed) unless a note on the bridge plans specifies that a qualified special mortar may be used.

2.3 The existing slab for the bridge(s) to be redecked was constructed as composite or non-composite as shown in the table below.

Bridge No.	Type of deck
A3040	Composite

2.4 Provisions shall be made to prevent any debris and material from falling into the waterway. If determined necessary by the engineer, any debris and material that falls below the bridge outside the previously specified limits shall be removed as approved by the engineer at the contractor's expense.

2.5 Any damage sustained to the remaining structure as a result of the contractor's operations shall be repaired or the material replaced as approved by the engineer at the contractor's expense.

2.6 Provisions shall be made to prevent damage to any existing utilities. Any damage sustained to the utilities as a result of the contractor's operations shall be the responsibility of the contractor. All costs of repair and disruption of service shall be as determined by the utility owners and as approved by the engineer.

2.7 A washer shall be required under head and nut when any reaming is performed for bolt installation.

2.8 SSPC-SP2 and SSPC-SP3 surface preparation shall be in accordance with the environmental regulations in [Sec 1081](#) and collection of residue shall be in accordance with [Sec 1081](#) for collection of blast residue. SSPC-SP6, SSPC-SP10 and SSPC-SP11 surface preparation shall be in accordance with the approved blast media and environmental regulations in [Sec 1081](#) and collection of blast residue shall be in accordance with [Sec 1081](#).

3.0 Coating Information.

3.1 Straps Removal. Exposed portions of straps for stay-in-place forms shall be removed prior to surface preparation. Straps need not be removed in areas that are not being painted. Flame

JOB SPECIAL PROVISIONS (BRIDGE)

cutting will not be permitted. The contractor shall exercise care not to damage the existing structure during removal. Any damage sustained to the remaining structure as a result of the contractor's operations shall be repaired or the material replaced as approved by the engineer at the contractor's expense.

3.2 Slab Drains and Stay-In-Place Forms. The stay-in-place forms, slab drains and slab drain brackets shall not be recoated, overcoated or damaged during the painting operation. Any portion of the slab drain bracket that is blast cleaned shall be recoated with System G. Any damage sustained as a result of the contractor's operations shall be repaired or the material replaced as approved by the engineer at the contractor's expense.

3.3 Existing Bridge Information. The informational plans may be used by bidders in determining the amount of steel to be cleaned and painted/coated with the full understanding that the State accepts no responsibility for accuracy of the estimated tons of existing steel shown in the table below. The bidder's acceptance and use of the estimate shown below shall be no cause for claim for any final adjustment in the contract unit price for the work involved in repainting. Each bidder is expected to carefully examine the structure(s), investigate the condition of existing paint and prepare their own estimate of quantities involved before submitting a bid. Surface preparation and applying field coatings to the structural steel shall be based on the contract plan quantities. No final measurements will be made.

Bridge No.	Estimated Tons			Existing Paint System	Lead Based
	Coating System		Total		
	System G	Calcium Sulfonate			
A3040	17.5	0	17.5	S	Yes

3.4 Environmental Contact. Environmental Section may be contacted at the below address or phone number. The Missouri Department of Health may be contacted at (573) 751-6102.

MoDOT - Design Division - Environmental Section
P.O. Box 270
105 W. Capitol Ave., Jefferson City, MO 65102
Telephone: (573) 526-4778

3.5 Approved Smelter and Hazardous Waste Treatment, Storage and Disposal Facility. The following is the approved smelter and hazardous waste treatment, storage and disposal facility:

Doe Run Company - Resource Recycling Division - Buick Facility
Highway KK
Boss, MO 65440
Telephone: (573) 626-4813

4.0 Method of Measurement. No measurement will be made.

5.0 Basis of Payment. Payment for the above described work will be considered completely covered by the contract unit price for other items included in the plans.

B. DEFLECTION AND HAUNCHING

JOB SPECIAL PROVISIONS (BRIDGE)

1.0 Description. The contractor shall determine dead load deflections and haunching based on field measurements and/or existing bridge plans and these shall be adjusted based on the difference between the new and existing dead load weights.

2.0 Construction Requirements. In order to properly form the haunches for the new deck, the contractor shall survey top of deck elevations above each beam including centerline of roadway and along each beam line (top or bottom flange) prior to deck removal followed by surveying elevations of the beams (top or bottom flange) after deck removal.

3.0 Method of Measurement. No measurement will be made.

4.0 Basis of Payment. Payment for the above described work will be considered completely covered by the contract unit price for other items included in the contract.

C. FIBER REINFORCED POLYMER (FRP) WRAP FOR CONCRETE BEAMS

1.0 Description. This work shall consist of designing, furnishing, and placing carbon or glass fiber reinforced polymer (FRP) composite wrap to shear strengthen the concrete beam at the locations as shown on bridge plans and as directed by the engineer.

2.0 Materials. The storage and handling of materials for the FRP composite work shall be in accordance with the manufacturer's written recommendations in factory sealed containers with the FRP manufacturer's labels. Labels shall be intact and legible with date of manufacture and shelf life.

2.1 Material Properties.

2.1.1 The contractor shall provide a unidirectional, high-strength fiber fabric fully saturated with compatible epoxy resin per manufacturer's recommendations. FRP provided shall meet or exceed ASTM D3039 test procedure requirements (tensile modulus, stress and strain) as determined from independent laboratory testing.

2.1.2 The contractor shall provide a flexible, waterproofing, non-vapor barrier protective top coating compatible with the FRP manufacturer's recommendations to protect the FRP from ultraviolet radiation and heavy abrasion with a design life of 50 years. This protective top coating shall closely match the gray color appearance of the existing concrete color.

2.2 Product Data. Manufacturer's product data including physical and chemical characteristics, material specifications for each component, limitations on use of the system, construction or application specifications, maintenance instructions and general manufacturer's recommendations regarding each system shall be provided. Product data on the proposed primer, putty, resin, saturant, and carbon or glass fiber shall be included. Testing information on the combination of the proposed carbon or glass fiber reinforcement and epoxy when used together as a system shall be provided. The contractor shall provide certifications by the producers of the materials that all materials supplied are in accordance with all the requirements and standards of the appropriate ASTM and other agencies. Manufacturer's Material Safety Data Sheets (MSDS) for all materials to be used shall be provided.

2.3 Contractor Submittals. The contractor shall submit the following documentations and obtain approval 30 days before work commences.

2.3.1 Contractor Qualifications. The contractor shall provide a manufacturer's certification of technical training, FRP system selected, project supervisor, and documentation showing the contractor has been certified or approved by the manufacturer of the FRP system. A contractor specializing in the supply and installation of FRP repair systems with minimum of 5 years of documented experience or 25 documented similar field applications with acceptable reference letters from respective owners in performing FRP composite retrofits shall perform the work. A trained project supervisor shall remain at the work site at all times to instruct the work crew in the FRP application procedures.

2.3.2 Shop Drawings. Shop drawings shall be submitted signed and sealed by a Missouri Professional Engineer in accordance with [Sec 107](#) for Authentication of Certain Documents. Shop drawings shall include the detail of types, locations, dimensions, number of layers and splice details and orientation of all FRP materials and coatings to be installed.

2.3.3 Calculations.

2.3.3.1 Concrete Beam Shear Strengthen. Signed and sealed calculations with the shop drawings shall be submitted indicating that the proposed system provides the additional design forces required at the locations indicated on the plans. The fiber reinforced polymer wrapping shall be designed in accordance with NCHRP Report 678, Design of FRP System for Strengthening Concrete Girders in Shear.

3.0 Construction Requirements.

3.1 FRP Wrapping. FRP shear reinforcement shall be by complete wrapping except where objects interfere, in those places U-wrap shall be used. FRP wrapping along the portion of the member length to be strengthened may be applied continuously or as discrete strips with a maximum of 12" spacing centerline to centerline. Fibers in the FRP in its final position on the concrete component shall be oriented in the direction that maximizes the effectiveness of the FRP reinforcement. Anchorage shall be required for U-wrap and overlap shall be required for complete wrap as per the manufacturer's recommendation. Additional horizontal strips of FRP shall not be used as anchorage for FRP shear reinforcement. The FRP shear strengthening shall be installed during the process of reconfiguring the steel girders and replacing the bearings at Int. Bents No. 3 & 6.

3.2 Concrete Moisture Requirement. The surfaces of the concrete to receive the FRP composite shall be reasonably dry based on the following test. A 3 x 3 foot polyethylene sheet shall be taped to the existing concrete surface and at any substructure repair area. If moisture collects on the underside of the polyethylene sheet before the epoxy would cure, the concrete shall be allowed to dry longer. The concrete surface shall pass this test before the FRP can be applied.

3.3 Surface Preparation. Spalled and loose concrete shall be removed and concrete surfaces restored to their original dimensions using substructure repair in accordance with [Sec 704](#). The new concrete in the substructure repair areas shall cure for a minimum of 28 days before the FRP is applied. Concrete surfaces of existing or patched concrete to receive an application of FRP material shall be prepared by abrasive blasting or grinding to remove existing laitance and expose aggregate to a minimum ICRI-CSP3 concrete surface profile. All FRP contact surfaces shall have all laitance, dust, dirt, oil, curing compound, existing coatings and any other foreign matter removed that could interfere with the bond between the FRP system and the concrete. Localized out-of-plane variations, including form lines, shall not exceed the smaller of 1/32 inch or the tolerances recommended by the FRP manufacturer's recommendation. Sharp and

JOB SPECIAL PROVISIONS (BRIDGE)

chamfered corners shall be rounded off to a minimum radius of 1/2 inch by grinding or forming with the system's thickened epoxy. Variations in the radius along the vertical edge shall not exceed 1/2 inch for each foot of length.

3.4 Installation of FRP. The concrete and atmospheric temperatures shall be between 40°F and rising and 90°F and falling during installation of the FRP. Tension adhesion testing shall be conducted using ASTM D7234 with the strengths reaching 200 psi. Any failure shall exhibit failure of the concrete substrate before failure of the adhesive. Tension adhesion testing shall cease when strengths reach 200 psi. Any failure of the concrete substrate and/or FRP adhesion shall be repaired at the contractor's expense and as directed by the engineer. Two adhesion tests shall be performed for each bent having FRP being applied. The FRP shall be installed in accordance with the manufacturer's written recommendations and as required by the job special provisions.

4.0 Method of Measurement. Fiber reinforced polymer wrap will be measured to the nearest square foot based on the member surface area as detailed on the contract plans. No additional compensation will be given for the use of multiple layers of material to achieve design strength. Final measurements will not be made except for authorized changes during construction or where significant errors are found in the contract quantity. The revision or correction will be computed and added to or deducted from the contract quantity.

5.0 Basis of Payment. Payment for the above described work, including all material, equipment, labor and any other incidental work necessary to complete this item, will be considered completely covered by the contract unit price for Fiber Reinforced Polymer Wrap.

D. NON-DESTRUCTIVE TESTING

1.0 Description. This work shall consist of performing non-destructive testing on the welds of all existing top flange cover plates.

2.0 Construction Requirements.

2.1 After the concrete deck is removed, the steel that is to remain will be inspected by the engineer. In addition to this inspection, the welds and adjacent base metal at the ends of the top cover plates shall have non-destructive (magnetic particle) testing performed. Non-destructive testing shall be performed by an acceptable testing agency. The contractor shall submit to the engineer and Bridge Division (Fabrication@modot.mo.gov) the following documentation for each individual performing non-destructive testing (NDT): their certifications, current eye exam and the NDT company written practice, including the Level III individual certification used for written practice. Personnel performing the tests shall be qualified for SNT-TC-1A Level II.

2.2 The length of weld to be tested and the base metal, one inch either side of the weld, shall be cleaned of all rust prior to the testing. On cover plates with square ends, the weld shall be tested one inch from each corner along the ends of the cover plate plus 6 inches back along the side from each corner of the plate. On cover plates with tapered ends, the weld shall be tested along the end of the cover plate, along tapered edges and 6 inches back along the cover plate from end of taper.

2.3 If fatigue cracks are found, the cracks are expected to be very small and may be located in the base metal at the toe of the welds. Any cracks discovered by testing, regardless of length, shall be marked and reported to the engineer. All repairs shall be made by a certified welder in

JOB SPECIAL PROVISIONS (BRIDGE)

accordance with [Sec 712.6](#). Any repair work and retesting of the repair work required, as a result of this inspection, will be paid for in accordance with [Sec 109](#). This shall not relieve the contractor from responsibility to repair any damage caused by this work at the contractor's expense. Any delay or inconvenience caused by this inspection requirement will be non-compensable and effect on time of performance non-excusable.

3.0 Method of Measurement. Measurement of non-destructive testing will be to the nearest linear foot. The extent of non-destructive testing may vary from the estimated quantities, but the contract unit price shall prevail regardless of the variation. Final measurements will not be made except for authorized changes during construction, or where appreciable errors are found in the contract quantity. The revision or correction will be computed and added to or deducted from the contract quantity.

4.0 Basis of Payment. Accepted quantities of non-destructive testing will be paid for at the contract unit price. Payment for the above described work, including all material, equipment, labor and any other incidental work necessary to complete this item, will be considered completely covered by the contract unit price for Non-Destructive Testing.

E. STRUCTURAL STEEL REQUIREMENTS

1.0 Description. This provision contains general structural steel requirements for this project.

2.0 Material. All material shall be in accordance with Division 1000, Material Details, and specifically as shown below. The gray epoxy-mastic primer (non-aluminum) shall be compatible with concrete and produce a dry film thickness of no less than 3 mils (75 µm).

Item	Section
Structural Steel Construction	712
Gray Epoxy-Mastic Primer (non-aluminum)	1045
Structural Steel Fabrication	1080
Coating of Structural Steel	1081

3.0 Construction Requirements.

3.1 Before fabrication of new metalwork, the contractor shall make the necessary measurements in the field to verify dimensions of the existing structure where new members are affected. Any deviation of the dimensions shown on the plans shall be called to the engineer's attention. The contractor shall be responsible for developing all required dimensional adjustments and coordinating the implementation of the dimensional adjustments with all involved fabricators and subcontractors.

3.2 Prior to erection of the new structural steel, the steel that is to remain shall be carefully inspected for irregularities. If such irregularities are found, the irregularities shall be brought to the attention of the engineer.

3.3 Holes in the new splice plates may be used as a template for drilling the holes in the existing material.

3.4 A minimum edge distance shall be maintained for all field drilled holes. The minimum edge distance for bolts shall be as shown in table below measured from the centerline of holes.

JOB SPECIAL PROVISIONS (BRIDGE)

Bolt Diameter	Minimum Edge Distance
inch (mm)	inch (mm)
3/4 (19.0)	1-1/4 (32)
7/8 (22.2)	1-1/2 (38)
1 (25.4)	1-3/4 (45)

3.5 The surfaces of existing steel that will become faying surfaces for non-slip critical new connections, typically secondary members, shall be cleaned according to the manufacturer's recommendation and with a minimum of SSPC-SP-3 surface preparation and coated with one prime coat of Gray Epoxy-Mastic Primer (non-aluminum) in accordance with [Sec 1081](#). The surfaces of existing steel that will become faying surfaces for slip critical new connections, typically primary members, shall be in accordance with contact surfaces in [Sec 1081](#). Primary member connections include girder/beam splices, end diaphragms and intermediate diaphragms in curved structures.

3.6 Exposed girder/beam areas that are not faying surfaces or not covered by concrete that are scratched, damaged by the contractor or by field welding operations shall be touched up with Gray Epoxy-Mastic Primer (non-aluminum) in accordance with [Sec 1081](#). The areas shall receive the coating system as shown on the plans.

4.0 Method of Measurement. No measurement will be made.

5.0 Basis of Payment. Payment for the above described work will be considered completely covered by the contract unit price for the structural steel items included in the contract. No payments or adjustments will be made where new members are affected due to any deviation of the dimensions shown on plans or shop drawings.

E. RECONFIGURE EXISTING STRUCTURAL STEEL

1.0 Description. This work shall consist of furnishing the necessary materials, labor, and equipment for removal of the existing shelf system and adjacent structural steel, within the limits shown on the plans, near Intermediate Bents No. 3 & 6. Any existing bolts in the diaphragms that are loosened or removed shall be replaced with new like-kind high strength bolts and installed in accordance with [Sec 712](#). Temporary support loads are provided in the bridge plans. The installation of the new structural steel spliced to the existing structural steel will make the bridge superstructure continuous for its entire length. This work shall be done as specified herein and in accordance with [Sec 712](#), [Sec 1080](#) and the bridge plans.

2.0 Supporting the Superstructure.

2.1 The existing bridge deck shall be removed before the existing structural steel is reconfigured. Before commencing operations, the Contractor shall submit to the Engineer complete working plans for the temporary support of the girders and the method and sequence of operations proposed in performing this work for review. The working plans shall be signed, sealed and stamped by a registered professional engineer in the State of Missouri in accordance with Authentication of Certain Documents in [Sec 107](#). The reconfiguration of existing structural steel shall be done only when authorized, but such authorization shall not relieve the contractor of responsibility for the safety of the operation or for damage to the structure.

JOB SPECIAL PROVISIONS (BRIDGE)

2.2 The Contractor shall exercise caution during the entire operation to protect the bridge from damage. Any damage to the existing structure as a result of this work shall be repaired to the satisfaction of the Engineer at the Contractor's expense.

2.3 The contractor shall visually inspect the area of girder for any damaged welds or other irregularities. Any damaged welds shall be repaired as directed by the engineer. If any irregularities are found, the irregularities shall be brought to the attention of the engineer.

2.4 The existing steel contact surfaces that will become faying surfaces for the slip critical bolted splice connections shall have the surface preparation prepared in accordance with Recoating of Structural Steel (System G, H or I) in [Sec 1081](#) and contact surfaces shall be in accordance with Protective Coating of Structural Steel in [Sec 1081](#).

3.0 Method of Measurement. Measurement for Reconfigure Existing Structural Steel will be in accordance with Sec. 7.12.11.1.

4.0 Basis of Payment. Payment for the above described work including all removals, material, labor, tools, equipment, temporary jacks, temporary shoring, and all incidentals necessary to complete this item of work will be considered completely covered by the contract lump sum price for Reconfigure Existing Structural Steel.

G. REMOVAL OF EXISTING BEARINGS

1.0 Description.

1.1 With the deck removed, this work shall consist of but is not limited to raising and supporting existing girders and/or beams at the locations specified on the plans, removing and disposing of the existing bearings and anchor bolts and performing all other required preparations prior to installing new bearings and anchor bolts as shown on plans.

1.2 The responsibility for the design and construction of falsework required to support the girders and/or beams during bearing removal and new bearing installation shall rest solely with the contractor. The design shall ensure that the falsework can support all applicable dead loads and any construction loads. The design shall also provide an adequate factor of safety when selecting the temporary support members. The falsework design and working plans including detailed computations shall be signed, sealed and stamped by a registered professional engineer in the State of Missouri in accordance with Authentication of Certain Documents in [Sec 107](#).

1.3 Existing girders and/or beams shall be subject to minimal construction loading by performing this work with the existing deck removed.

1.4 Existing bearing top plates shall be removed and girder and/or beam surfaces cleaned and coated before placement of new bearings. The removal of the existing bearing top plate and cleaning shall be completed in such a manner as to not cause any damage to the existing bottom flange. Method of removal shall be as approved by the engineer.

2.0 Construction Requirements and Materials.

2.1 Raising and Supporting the Superstructure.

2.1.1 Before beginning operations, the contractor shall submit to the engineer for review the method and sequence of operation proposed to be used in performing this work. With the deck

JOB SPECIAL PROVISIONS (BRIDGE)

removed, the contractor shall exercise caution when supporting the structural steel and shall raise the girders and/or beams the minimum extent necessary to perform this work with a maximum raise of 1/4 inch. Raising the girders and/or beams at the location of reset bearings shall be performed in a manner to prevent any damage to the adjoining steel. The lifting operation shall be performed only when authorized, but such authorization shall not relieve the contractor of responsibility for the safety of the operation or for damage to the structure. Any damage caused by the contractor's operations shall be repaired at the contractor's expense as approved by the engineer.

2.1.2 Temporary timber supports (bearing stiffeners) shall be placed between the girder and/or beam flanges at each jacking location to prevent flange rotation. Permanent steel stiffening angles shall be designed and attached to the beam web when the beam web thickness is not adequate to support the jacking load.

2.1.3 Raising the girders and/or beams shall be performed simultaneously and shall be performed in a manner to prevent any damage to the adjoining steel.

2.1.4 Existing end diaphragms at bent may require loosening or be completely removed in order to install new anchor bolts and bearings as authorized by the engineer.

2.1.5 Bolts of existing end diaphragms that must be loosened or removed shall be replaced with like size galvanized high strength bolts with washer under head and nut.

2.2 Bearing Removal.

2.2.1 After the structural members are supported, the contractor shall remove the existing bearings.

2.2.2 The contractor shall remove the existing anchor bolts to one inch below the concrete surface or to the extent needed for installation of the new anchor bolts as required by the plans and as authorized by the engineer. The resultant holes shall be filled with a qualified special mortar in accordance with [Sec 704](#).

2.3 Cleaning and Painting. Faying surfaces where existing end diaphragms will be reconnected and inside of drilled holes and the bottom surface of existing flange which will become faying surfaces of new connections shall be cleaned and painted with one coat of gray epoxy-mastic primer (non-aluminum).

3.0 Method of Measurement. Final measurement for removal of the existing bearings and preparation for the installation of the new bearings will be made per each.

4.0 Basis of Payment. Payment for furnishing and placing all temporary falsework (including stiffeners), materials, removals, disposal of all falsework, labor, tools, equipment and all incidentals necessary to complete this item will be considered completely covered by the contract unit price for Removal of Existing Bearings.